

STATE OF NEBRASKA



Dave Heineman
Governor



Jim Heine
Fire Marshal

June 24, 2014

Kimberly Lingenfelter, Superintendent
Neligh-Oakdale Public School
P.O. Box 149
Neligh, NE 68756

Mrs. Lingenfelter,

Thank you for your response with the June 9, 2014-Plan of Correction for the Orders written in regards to the inspection conducted on April 30, 2014. The following are adjustments/comments that have been made for the Plan to be acceptable to this office.

1. & 2. The conditions that are present with reference to no egress windows and student occupancy in the basement are acceptable when the building is protected by a supervised automatic fire sprinkler system. With the Plan to have this completed by August, 2015, efforts shall be made to make these spaces as safe as possible for the 2014-2015 school year. This may include, but not limited to, the installation an egress window in basement classrooms, the addition of extra fire alarm detection and notification, and additional fire drills. Further discussion is required in this area.

5. Even with the future sprinkler protection, all storage rooms are still required to be separated by smoke resisting construction to include solid doors and door closers on hazardous areas.

6. Although there is an exception for corridor protection for fully sprinkler protected buildings, the walls are required to be constructed as a smoke partition to include doors with no openings.

Exception No. 2: In buildings protected throughout by an approved automatic sprinkler system with valve supervision in accordance with Section 9.7, corridor walls shall not be required to be rated, provided that such walls form smoke partitions in accordance with 8.2.4.*

8. Shall be completed by September 1, 2014

9. Shall be completed by September 1, 2014

□ **MAIN OFFICE**
□ **DISTRICT A**
246 South 14th Street
Lincoln, NE 68508-1804
(402) 471-2027

□ **DISTRICT B**
438 West Market
Albion, NE 68620-1241
(402) 395-2164

□ **FUELS DIVISION**
□ **FLST** □ **Pipeline**
246 South 14th Street
Lincoln, NE 68508-1804
(402) 471-9465

□ **TRAINING DIVISION**
2410 North Wheeler Avenue
Suite 112
Grand Island, NE 68801-2376
(308) 385-6892

I look forward to working with the Neligh-Oakdale Public School District to complete this Plan of Correction. I know that we have a mutual goal of providing a safe learning environment for students and protection to life in the event of a fire or other emergency. Please contact me at the 402-395-2164 if you have any questions.



Sean Lindgren
Chief Deputy State Fire Marshal

Cc: Don Fritz, Assistant State Fire Marshal
Cc: Nick Bentz, Deputy State Fire Marshal

☐ **MAIN OFFICE**
☐ **DISTRICT A**
246 South 14th Street
Lincoln, NE 68508-1804
(402) 471-2027

☐ **DISTRICT B**
438 West Market
Albion, NE 68620-1241
(402) 395-2164

☐ **FUELS DIVISION**
☐ **FLST** ☐ **Pipeline**
246 South 14th Street
Lincoln, NE 68508-1804
(402) 471-9465

☐ **TRAINING DIVISION**
2410 North Wheeler Avenue
Suite 112
Grand Island, NE 68801-2376
(308) 385-6892